

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit Breaker for Overcurrent Protection

Name and address of the applicant

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China

Name and address of the manufacturer

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China

Name and address of the factory

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China

Ratings and principal characteristics

Ue: AC 220V/380V, 230V/400V, 240V/415V (1P); AC 220V/230V/
240V (1P+N, 2P); AC 380V/400V/415V (2P, 3P, 3P+N, 4P);
In: 1A, 2A, 3A, 4A, 5A, 6A, 10A, 16A, 20A, 25A, 32A, 40A,
50A, 63A; Ics=Icn: 4500A for 1), 6000A for 2); Type B, C, D

Trademark (if any)

Tengen (Logo)

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

1) TGB1N-63A
2) TGB1N-63

Additional information (if necessary may also be reported on page 2)

Detailed information refer to test report CN2100SH 001.

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

CN2100SH 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2022-03-04

Signature: Wencai Zhang