



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

**Certificate No.: CE200311007057**

**Product** Household AC contactor

**Applicant** Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

**Type/Model** TGCH1N-32, TGCH1N-40, TGCH1N-63

**Technical data** Uimp:4kV; Ui:500V; Ith:63A;  
Ue:AC250V(1P,2P),AC400V(3P,4P);  
TGCH1N-32:Ie:32A(AC-7a),12A(AC-7b);  
TGCH1N-40:Ie:40A(AC-7a),15A(AC-7b);  
TGCH1N-63:Ie:63A(AC-7a),20A(AC-7b); AC-7a,AC-7b;  
Us:AC24V,AC48V,AC110V,AC230V,50/60Hz; 1P,2P,3P,4P

This is to certify that, on the basis of the tests undertaken as per Report No.  
C-14201-DC195135, the submitted sample(s) of the above item complies with:

**EN 61095:2009**

and fulfills testing requirements of the European Directive:

**Low Voltage Directive (LVD): 2014/35/EU**

**Valid from:** Dec.30,2020

**Valid until:** Dec.30,2023

**President:**

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**  
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>