



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

**Certificate No.: CE160305004991-A1/H1**

**Product** Thermal overload relay

**Applicant** Zhejiang Tengen Electric Co.,Ltd.  
 Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
 Province, P.R.China

**Type/Model** TGR1-18,TGRH-18

**Technical data**

Uimp:6kV;Ui:690V; Ue:690V;Ie: 0.1~0.16A,0.16~  
 0.25A,0.25~0.4,0.4~0.63,0.63~1A,1~1.6A,1.6~  
 2.5A,2.5~4A,4~6A,5.5~8A,7~10A,9~13A,12~  
 18A;Tripping class:10A;3P;IP20;Auxiliary  
 contacts:1NO,1NC;Ith:5A;AC-15:Ue/Ie220V/1.64A,380V/0.  
 95A;DC-13:Ue/Ie220V/0.15A

This is to certify that, on the basis of the tests undertaken as per Report No.  
 00901-CE2016CQC0305-007762-A1/H1, the submitted sample(s) of the above item  
 complies with:

**EN 60947-4-1:2010 + A1:2012**

and fulfills testing requirements of the European Directive:  
**2014/35/EU**

**Valid from:** May.16,2019

**Valid until:** May.16,2022

**President:**

*陆梅*

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**  
 Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>