



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

**Certificate No.: CE210304007212**

**Product** Switch-disconnectors

**Applicant** Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

**Type/Model** TGH1N-125

**Technical data** See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.  
CE-045-1C200940, the submitted sample(s) of the above item complies with:

**EN 60947-3:2009 + A1:2012**

and fulfills testing requirements of the European Directive:

**Low Voltage Directive (LVD): 2014/35/EU**

**Valid from:** Apr.28,2021

**Valid until:** Apr.28,2024

**President:**

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

Appendix

Page 1 of 1

Certificate No.: CE210304007212

TGH1N-125

Uimp:6kV;

Ui:690V;

Ue:AC220V/AC230V/ AC240V (1P),AC380V/AC400V/ AC415V (2P,3P,4P);

Ith:63A(20A,25A,32A,40A,50A,63 A),125A(80A,100A, 125A);

Ie:20A,25A, 32A,40A,50A,63A,80A,100A,125A;

Icw:

756A/1s(20 A,25A,32A,40A,50A,63 A),

1.5kA/1s(80A,100A,125A);

Icm:

1.26kA(20A,25A,32A,40A,50A,63 A),

2.5kA(80A,100A, 125A);

AC-22A,AC-21B;

50/60Hz;

IP20;

1P,2P,3P,4P

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>